

# **FEATURES & SPECIFICATIONS**

## **INTENDED USE**

Designed for low to medium mounting heights. Ideal for applications where dirt, dust, humidity, moisture and cold temperatures are present. **Certain airborne contaminants can diminish integrity of acrylic. Click here for Acrylic Environmental Compatibility table for suitable uses.** 

### CONSTRUCTION

Rugged light gray polycarbonate housing with continuous poured gasket for an airtight seal, keeping out moisture, dust and humidity. Cold-rolled steel enclosed wireway included.

Provided with one open hole and knockout at opposite end.

## **OPTICS**

UV stablized, impact-resistant, polycarbonate lens. Ten (10) snap-fit polycarbonate latches attach the lens to the housing for a tight seal.

### **ELECTRICAL SYSTEM**

Standard electronic ballast (120-277V, 60Hz) ensures no flickering and quiet operation.

Starts instantly down to 0°F (-18°C) with two 32W linear T8 lamps and with two 54W linear T5HO lamps (lamps not included).

### INSTALLATION

Two stainless steel mounting brackets included, which allow for flush or chain mounting (chain not included).

### LISTINGS

UL listed to US and Canadian safety standards. UL listed for 25°C ambient and wet locations. IP65 rated.

### WARRANTY

Fixtures, including ballasts, are covered by the Lithonia Lighting 24-month warranty against mechanical defects in manufacture.

Catalog Number			
Notes			
Туре			

**Contractor Select** 

# Industrial Wet Location



## ORDERING INFORMATION

Catalog		Lamp	Pallet	Standard Carton					
Number	UPC	Description	Lamps	Wattage	Voltage	Included	Qty.	Qty.	
XWL232 MV	745975639755	Enclosed industrial	2	32	120-277	N	63	1	
XWL254 MV	745976008697	Enclosed industrial	2	54	120-277	N	63	1	

# Accessories: Order as separate catalog number.

DXWL48 Enclosed industrial replacement lens.

XWL LATCH M10 Enclosed industrial replacement latch.

### Notes

1 CSA products come standard with probe-start ballasts.

# **Industrial Wet Location**

TEST NO: LTL16355 LUMINAIRE CATALOG NO.:XWL 2 32 LUMENS PER LAMP2850

Coefficients of Utilization

pf	20%											
рс	80% 50% 30% 10%				70% 50% 30% 10%				50% 50% 30% 10%			
pw				50								
1	69	65	62	6	7	63	60		63	60	57	
2	59	53	48	5	7	52	47		53	49	45	
22 3 22 4	51	44	39	4	9	43	38		46	41	37	
<b>∝</b> 4	45	38	32	4	3	37	32		41	35	30	
5	40	33	27	3	8	32	27		36	30	26	
10	24	19	15	2	4	18	14		23	18	14	

# Zonal Lumen Summary

Zone	Lumens	% Lamp	% Fixture
0° - 30°	754.0	13.2	18.5
0° - 40°	1258.5	22.1	30.8
0° - 60°	2366.6	41.5	58.0
0° - 90°	3711.0	65.1	90.9
90° - 180°	372.4°	6.5	9.1
0° - 180°	4083.4	71.6	100.0

TEST NO: LTL18259 LUMINAIRE CATALOG NO.:XWL254 MV LUMENS PER LAMP:4450 Luminaire Efficiency: 70.3%

			Coe	efficie	nts of U	tilizat	ion					
pf												
рс		)%			70%			50%				
pw	70%	50%	30%	10%	50	50% 30% 10%			50% 30% 10%			
0	83	83	83	83	80	80	08 (	76	76	76		
1	73	68	64	60	66	62	2 59	62	59	56		
2	65	58	52	47	56	50	46	52	48	44		
3	58	49	43	37	48	42	2 37	45	40	35		
~ <sup>4</sup>	53	43	36	31	42	35	30	39	34	29		
RCR 2 2	48	38	31	26	37	30	25	35	29	25		
<sup>LL</sup> 6	44	34	27	22	33	27	22	31	26	21		
7	41	31	24	19	30	24	19	28	23	19		
8	38	28	21	17	27	21	17	26	20	16		
9	36	26	19	15	25	19	15	24	18	15		
10	33	23	18	14	23	3 17	' 14	22	17	13		

# Zonal Lumen Summary

Zone	Lumens	% Lamp	% Fixture
0° - 30°	1121.8	12.6	17.9
0° - 40°	1852.5	20.8	29.6
0° - 60°	3572.1	40.1	57.1
0° - 90°	5869.2	65.9	93.8
90° - 180°	390.3	4.4	6.2
0° - 180°	6259.4	70.3	100.0

